

High Spatial Resolution Measurements of the Electric Field in a Hollow Cathode Discharge

K. Grützmacher¹, C. Pérez¹, L M Fuentes^{1,2} and M I de la Rosa¹

¹*Dep. de Física Teórica, Atómica y Óptica, Universidad de Valladolid, 47011 Valladolid, Spain*

²*Dep. de Física Aplicada, Universidad de Valladolid, 47011 Valladolid, Spain*

Hollow cathode discharges (HCD) are the subject of an intense research mainly due to the increasing number of technological applications. To improve all these applications it is very important a clear understanding of the different mechanisms involved in the discharge [1]. The local electric field strength (E-field) is one of the most relevant discharge parameters because it is connected with charged particle fluxes, their energy distribution functions and the charge densities. In this type of discharges (HCD) the E-field distribution shows a very strong gradient in a very short region adjacent to the cathode surface (dark space), where almost the entire potential applied between the electrodes drops off. As a consequence E-field measurements demand a high spatial resolution. This work is dedicated to study the E-field in the dark region of a HCD in different experimental conditions of pressure and current; using two gasses: hydrogen or deuterium [2, 3]. With the results it is possible to compare in detail similarities and differences in the tendencies of the cathode fall characteristics of a HCD operated in both gasses, hence the similarities and differences will be only related to the change of atomic and molecular mass by a factor of two (D with respect to H), while all other atomic and molecular parameters (e.g. dissociation and ionization energy) are nearly identical.

The E-field strength was determined via the Stark splitting of the 2S level of the atomic hydrogen isotopes using Doppler-free two-photon optogalvanic spectroscopy. The E-field varies from 0.5 kV/cm to 4 kV/cm in the cathode fall region of about 2 mm. The exceptional high spatial resolution provided by the optogalvanic detection in our experiment [4] gives reliability to the obtained experimental results, which we will show at the Conference, i.e.: maximum E-field at the cathode surface, cathode sheath thickness, and variations of the cathode fall voltage drop versus pressure and current.

The present work was supported by the DGICYT (Ministerio de Economía y Competitividad) contract reference number ENE2012-35902 and FEDER funds.

[1] N. Baguer, A. Bogaerts and R. Gijbels, *Spectrochimica Acta Part B* **57** (2002)

[2] M. I. de la Rosa, C. Pérez, K. Grützmacher and L.M. Fuentes, *Plasma Sources Sci. Technol.* **18**, 015012 (2009)

[3] C. Pérez, M.I. de la Rosa and K. Grützmacher, *Eur. Phys. J. D* **56**, 369 (2010)

[4] M. García Lechuga, L. M. Fuentes, K. Grützmacher K., C. Pérez and M. I. de la Rosa, 8th Iberoamerican Optics Meeting and 11th Latin American Meeting on Optics, Lasers, and Applications, 87854F (November 18, 2013); doi:10.1117/12.2026186